



Materialprüfung und Entwicklung
GmbH & Co. KG

Geschäftsführer: Jens Hellberg
Artlenburger Landstraße 39 - 41
21365 Adendorf
Tel.: +49 4131 88 43 947
Fax: +49 4131 88 43 948
Email: hellberg@mpi-pruefinstitut.de
Internet: www.mpi-pruefinstitut.de

Test certificate No.: 12 7638 - S / 16

Date: 07.03.2016

Page 1 of 2

Customer: Asphalt Art International AG
Bahnhof-Park 3
6340 Baar
Switzerland

Order No.: n.n.

Date of order: 16.02.2016

Type of test: Testing of floorcoverings in accordance with DIN 51130, Slip Resistance "Ramp Test".

Testing material:

Trade name: self adhesive floor film, Type: CatWalk
(declaration by customer) unprinted

Format of test item: 100 cm x 50 cm (Length x Width)
(according to DIN 51130 / BGR181)

Surface structure: fine rough, smooth

The pages 1 and 2 show the complete test result. They may just be published together



Test certificate No.: 12 7638 - S / 16

Page 2 of 2

Test

Date of test: 19.02.2016

Standards / regulations: **DIN 51130 (Ausgabe 2014-02):** Bestimmung der rutschhemmenden Eigenschaft – Arbeitsräume und Arbeitsbereiche mit erhöhter Rutschgefahr.
BGR 181: Merkblatt für Fußböden in Arbeitsräumen und Arbeitsbereichen mit Rutschgefahr.

Joint width of item for testing: 0 mm

Test result:

Average angle: 17,1°

Average displacement: not tested

Classification: R 10

Classification of displacement: not applicable

Validity of this certificate

Owing to possible changes in regulations (test / standards) and technical innovations, the validity of this certificate is limited for the duration of 5 years until the 19.02.2021.

The test results are only valid for products which are identical with the tested item. The correlation between the item tested and the production lot is not controlled by MPI test lab!

General informations

Certificates may only be copied and published with permission of the MPI test lab without any changes. The publishing and copying of shortened versions is only permitted after consulting with MPI test lab.



MPI Materialprüfung und Entwicklung
(Leitung Jens Hellberg)