Łukasiewicz Instytut Ceramiki I Materiatów Budowlanych

Łukasiewicz Research Network - Institute of Ceramics and Building Materials

CERAMIC AND CONCRETE DIVISION IN WARSAW

02-676 Warszawa Postępu 9 Str., Poland phone: +48 22 847 00 87 a.ducka@icimb.pl 03-042 Warszawa Kupiecka 4 Str., Poland mobile: 601 370 583 m.piotrowicz@icimb.pl





RESEARCH LABORATORY

www.lcimb.pl

TEST REPORT NO 68/2/P/LB/2021(EN)

SUBJECT OF TESTING: SportWalk

ORDERER: Continental Grafix AG

Lettenstrasse 2 CH-6343 Rotkreuz

Switzerland

DATE OF RECEIPT THE SAMPLES: 15.03.2021 r.

DATE OF TESTS: 6 – 7.04.2021.

EXECUTOR: Technician Jacek Kamiński

M.Sc. Eng Marcin Pożarowszczyk

Number of copies: 1

Number of pages: 3

Warsaw, 8.04.2021

RESEARCH LABORATORY OF WP OCIB/Ł-ICIMB

TEST REPORT NO 68/2/P/LB/2021(EN)

page 2 / 3

1. Subject of testing

SportWalk

500 x 1000 mm

Producer: Continental Grafix AG

Lettenstrasse 2 CH-6343 Rotkreuz Switzerland

Number of sample: 1 piece Designation of sample: 53P/2021

The samples taken and delivered to the Research Laboratory by the Orderer.

2. Scope of tests and the place of their execution.

- determination of critical slip angle

Scope of tests has been established by the Customer.

Tests have been made in the Research Laboratory WP of Ceramics and Concrete Division.

3. Testing methods:

DIN 51130:2014–02 Testing of floor coverings. Determination of the anti-slip properties.

Workrooms and fields of activities with slip danger, walking

method. Ramp test.

4. Results of tests

4.1. Determination of critical slip angle.

According to DIN 51130:2014–02 Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test.

Sample size: 0,5 m²

Critical slip angle	
Adjusted average overall acceptable angle α ges	Anti-slip properties class
10,1	R 10

RESEARCH LABORATORY OF WP OCib/Ł-ICiMB

TEST REPORT NO 68/2/P/LB/2021(EN)

page 3 / 3

5.0. Statement.

5.1. Results of tests relate exclusively to tested objects.

5.2. Test report may be copied only as a whole, whereas for partial coping the consent of laboratory is required.

The person responsible for the report:

(Julo Agnieszka Ducka, M Sc The person authorizing the report:

Duda Mgr Amerza