



Materialprüfung und Entwicklung
GmbH & Co. KG

Geschäftsführer: Jens Hellberg
Artlenburger Landstraße 39 - 41
21365 Adendorf
Tel.: +49 4131 88 43 947
Fax: +49 4131 88 43 948
Email: hellberg@mpi-pruefinstitut.de
Internet: www.mpi-pruefinstitut.de

Test certificate No.: 12 11928 - S/ 25

Date: 11.08.2025

Page 1 of 2

Customer: Continental Grafix AG
Lettenstrasse 2
6343 Rotkreuz
Switzerland

Order No.: n.n.

Date of order: 23.06.2025

Type of test: Testing of floorcoverings in accordance with DIN EN 16165:2023-02, Determination of slip resistance of pedestrian surfaces, Annex A

Testing material:

Trade name: ClearWalk, self adhesive floorfilm
(declaration by customer)

Format of test item: ca. 100 cm x 40 cm (Length x Width)
(according to EN 16165, Annex A)

Surface structure: fine rough

The pages 1 and 2 show the complete test result. They may just be published together



Test certificate No.: 12 11928 – S / 25

Page 2 of 2

Test

Date of test: 17.07.2025

Standards / regulations: DIN EN 16165 :2023-02, Determination of slipresistance of pedestrian surfaces - Methods of evaluation, Annex A and Annex NB.1

Joint width of item for testing: 0 mm

Test result:

Ramp test value abarefoot: 18,0°

Classification: B

Validity of this certificate

Owing to possible changes in regulations (test / standards) and technical innovations, the validity of this certificate is limited for the duration of 5 years until the 17.07.2030.

The test results are only valid for products which are identical with the tested item. The correlation between the item tested and the production lot is not controlled by MPI test lab!

General informations

Certificates may only be copied and published with permission of the MPI test lab without any changes. The publishing and copying of shortened versions is only permitted after consulting with MPI test lab.



MPI Materialprüfung und Entwicklung
(Leitung Jens Hellberg)